Austrian Institute of Construction Engineering Schenkenstrasse 4 | T+43 1 533 65 50 1010 Vienna | Austria | F+43 1 533 64 23 www.oib.or.at | mail@oib.or.at





## European Technical Assessment

## ETA-15/0540 of 26.02.2021

General part

Technical Assessment Body issuing the European Technical Assessment

Trade name of the construction product

Product family to which the construction product belongs

Manufacturer

Österreichisches Institut für Bautechnik (OIB) Austrian Institute of Construction Engineering

SHERPA Power Base C, S and F

Three-dimensional nailing plate (Load-bearing connections between timber columns and basement)

Vinzenz Harrer GmbH Badl 31 8130 Frohnleiten Austria

Manufacturing plant

This European Technical Assessment contains

This European Technical Assessment is issued in accordance with Regulation (EU) No 305/2011, on the basis of

This European Technical Assessment replaces

Manufacturing plant 1

24 pages including 6 Annexes, which form an integral part of this assessment.

European Assessment Document (EAD) 130186-00-0603 "Three-dimensional nailing plates".

European Technical Assessment ETA-15/0540 of 07.10.2015.



## Remarks

Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and should be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may be made with the written consent of Austrian Institute of Construction Engineering. Any partial reproduction has to be identified as such.

#### Specific parts

#### 1 Technical description of the product

#### 1.1 General

This European Technical Assessment (ETA)<sup>1</sup> applies to the timber column bases **SHERPA Power Base C**, **SHERPA Power Base S** and **SHERPA Power Base F**. SHERPA Power Base is used in load-bearing connections between timber columns and basement.

**SHERPA Power Base C and S** is manufactured in the 5 different types, PB L 130 C, PB L 140 C, PB L 170 S, PB XL 120 C and PB XL 140 C, see Annex 2.

#### SHERPA Power Base C and S is comprised of:

- Base plate Type 1 or Type 2 installed to the basement
  - $\rightarrow$  Type 1: 140 x 140 x 12 mm with 4 boreholes Ø 15 mm or
  - $\rightarrow$  Type 2: 140 x 140 x 12 mm with 3 slotted holes 15 x 30 mm and 1 borehole Ø 15 mm
- Threaded rod (M30) mounted in the centre of the base plate by a weld or installed directly into the basement (in this case no base plate is necessary)
- Hollow tube (outer Ø 36 mm or 42 mm) with a thread (M30) inside mounted on the threaded rod for adjustment of the height
- Hat-shaped flange with a conical drilling inside placed on the top of the hollow tube in order to fix the end plate with a suitable conical counterpart with external thread (Ø 57 mm or 63.5 mm) or locking screw (Ø 40 mm) for Power base L 170 S
- Clamping nut for coupling of the two basic elements (except Power base L 170 S)
- End plate Type A, Type B, Type C, Type D or Type E, thickness 12 mm, installed at the timber column with screws of diameter 8 mm
  - → Type A: Ø 96 mm with 3 inclined boreholes Ø 9 mm
  - → Type B: Ø 106 mm with 3 inclined boreholes Ø 9 mm
  - → Type C: Ø 116 mm with 3 inclined boreholes Ø 9 mm
  - → Type D: Ø 126 mm with 3 inclined boreholes Ø 9 mm
  - → Type E: 100 x 100 with 3 inclined bore holes Ø 9 mm and 1 borehole Ø 9 mm

**SHERPA Power Base F** is manufactured in the 3 different types, PB M 125 F, PB L 125 F, and PB XL 95 F, see Annex 2.

### SHERPA Power Base F is comprised of:

- Base plate 100 x 160 x 10 mm with 4 boreholes Ø 15 mm installed to the basement
- Threaded rod (M24) mounted in the centre of the base plate by a weld or installed directly into the basement (in this case no base plate is necessary)

In 2015 ETA-15/0540 was firstly issued as European Technical Assessment ETA-15/0540 of 07.10.2015 and converted to ETA-15/0540 of 26.02.2021.



- Hollow tube (outer Ø 30 mm) with a thread (M24) inside mounted on the threaded rod for adjustment of the height
- Hat-shaped flange mounted to the end plate by 3 hexagon socket head cap screws (M6 x 12 mm) and a metal disc ( $\emptyset$  67 mm x 10 mm)
- End plate Type A, Type B, Type C, Type D or Type E, thickness 10 mm, installed at the timber column with screws of diameter 8 mm

According to the composition of the SHERPA Power Base, a separate assembly of the end plate to the timber column and the base plate with threaded rod and hollow tube to the basement is possible.

The anchorage of the sub construction (base plate or threaded rod) to the basement is not part of this ETA. Installation of the base plate is carried out with suitable fasteners. Installation of the threaded rod is carried out according to standards and regulations in force at the place of use.

SHERPA Power Base and the components for its manufacturing correspond to the specifications given in the Annexes 1 to 3. The material characteristics, dimensions and tolerances of SHERPA Power Base, not indicated in these Annexes, are given in the technical file<sup>2</sup> of the European Technical Assessment.

#### 1.2 **SHERPA** Power Base

Base plate, threaded rod, hollow tube, hat shaped flange and conical counterpart or locking screw or metal disc, clamping nut and end plate of SHERPA Power Base are produced of structural steel S235 according to EN 10025-2<sup>3</sup> or better with a minimum characteristic yield strength of  $R_{eH}$  = 235 MPa and a minimum characteristic tensile strength of  $R_m$  = 360 MPa.

The distance between the basement and the end plate of the SHERPA Power Base is given in Annex 2.

The timber column bases together with their most important dimensions are shown in Annex 3.

#### 1.3 Fasteners

The screws for installation of the end plate of SHERPA Power Base into the timber are described in Annex 1. They are made of carbon steel.

The hexagon socket head cap screws for mounting of the hat-shaped flange and a metal disc to the end plate of SHERPA Power Base F are produced according to EN ISO 4762. They are made of carbon steel.

#### 2 Specification of the intended use(s) in accordance with the applicable European Assessment Document (thereafter EAD)

#### 2.1 Intended use

SHERPA Power Base is used in load-bearing connections between timber columns and basement.

The timber columns may be of solid timber of strength class C24 or better according to EN 338 or glued laminated timber of strength class GL 24c or better according to EN 14080 with minimum dimensions 120 x 120 mm for fasteners Ø 8 x 160 mm and 140 x 140 mm for fasteners Ø 8 x 180 mm.

SHERPA Power Base shall be subjected to static and quasi static actions only.

electronic copy

The technical file of the European Technical Assessment is deposited at Österreichisches Institut für Bautechnik and, in so far as is relevant to the tasks of the notified factory production control certification body involved in the assessment and verification of constancy of performance procedure, is handed over to the notified factory production control certification body.

Reference documents are listed in Annex 6.



SHERPA Power Base is intended to be used in service classes 1 and 2 according to EN 1995-1-1. Ingress of moisture from outside and condensation must be excluded.

#### 2.2 General assumptions

SHERPA Power Base is manufactured in accordance with the provisions of the European Technical Assessment using the manufacturing process as identified in the inspection of the manufacturing plant by Österreichisches Institut für Bautechnik and laid down in the technical file.

The manufacturer shall ensure that the requirements in accordance with the Clauses 1, 2 and 3 as well as with the Annexes of the European Technical Assessment are made known to those who are concerned with design and execution of the works.

#### <u>Design</u>

The European Technical Assessment only applies to the manufacture and use of SHERPA Power Base. Verification of stability of the works including application of loads on the column bases is not subject of the European Technical Assessment.

The following conditions shall be observed:

- Design of connections with SHERPA Power Base is carried out under the responsibility of an engineer experienced in such structures.
- Design of the works shall account for the protection of the connections to maintain service class 1 and 2 according to EN 1995-1-1.
- SHERPA Power Base is installed correctly.
- It shall be checked in accordance with EN 1995-1-1 that splitting will not occur.
- SHERPA Power Base shall only be subjected to vertical tension loads, F<sub>1</sub>, in short-term and instantaneous load-duration classes.

Design of connections with SHERPA Power Base may be according to Eurocode 3 and Eurocode 5 taking into account the Annexes of the European Technical Assessment. Standards and regulations in force at the place of use shall be considered.

#### Packaging, transport, storage, maintenance, replacement and repair

Concerning product packaging, transport, storage, maintenance, replacement and repair it is the responsibility of the manufacturer to undertake the appropriate measures and to advise his clients on the transport, storage, maintenance, replacement and repair of the product as he considers necessary.

#### Installation

It is assumed that the product will be installed according to the manufacturer's instructions or (in absence of such instructions) according to the usual practice of the building professionals.

SHERPA Power Base shall be screwed as specified in Annex 3.

For the timber columns the following shall be observed:

- Solid timber of strength class C24 or better according to EN 338 or glued laminated timber of strength class GL 24c or better according to EN 14080;
- SHERPA Power Base shall be installed centrically in the cross-section of the timber column;
- The end grain of the timber column must be plane on the end plate of the SHERPA Power Base;
- The timber column shall be free from wane in areas in contact with the SHERPA Power Base;
- SHERPA Power Base shall be restrained against rotation;
- Minimum spacing and edge distances are in accordance with EN 1995-1-1.

ectronic copv



### 2.3 Assumed working life

The provisions made in the European Technical Assessment (ETA) are based on an assumed intended working life of the construction product of 50 years, when installed in the works, provided that the product is subject to appropriate installation, use and maintenance (see clause 2.2). These provisions are based upon the current state of the art and the available knowledge and experience<sup>4</sup>.

The indications given as to the working life of the construction product cannot be interpreted as a guarantee neither given by the product manufacturer or his representative nor by EOTA nor by the Technical Assessment Body, but are regarded only as a means for choosing the appropriate products in relation to the expected economically reasonable working life of the works.

#### 3 Performance of the product and reference to the methods used for its assessment

### 3.1 Essential characteristics of the product

#### Table 1: Essential characteristics and performances of the product

N⁰	Essential characteristic	Product performance		
	Basic requirement for construction works 1: Mechanical resistance and stability			
1	Joint strength	3.1.1		
2	Joint stiffness	No performance assessed		
3	Joint ductility	No performance assessed		
4	Resistance to seismic actions	No performance assessed		
5	Resistance to corrosion and deterioration	3.1.2		
	Basic requirement for construction works 2: Safety in case of fire			
6	Reaction to fire	3.1.3		
7	Resistance to fire	No performance assessed		

#### 3.1.1 Joint strength

The joint strength of SHERPA Power Base is determined by calculation assisted by testing. The end plate of SHERPA Power Base is installed with the defined number of screws with respective nominal diameter as specified in Annex 1 to Annex 3. Installation of the base plate to the basement is carried out with suitable fasteners.

The values of the characteristic load bearing capacities for the specified loading directions according to Annex 4 are given in Annex 5.

Imperfections of the timber columns are not included in the load-bearing capacities of the SHERPA Power Base.

#### 3.1.2 Resistance to corrosion and deterioration

The product is intended to be used in service classes 1 and 2 according to EN 1995-1-1 in low corrosive category according to EN ISO 12944-2.

The real working life of a product incorporated in a specific works depends on the environmental conditions to which that works is subject, and the particular conditions of the design, execution, use and maintenance of that works may be outside this ETA. Therefore, it cannot be excluded that in these cases the real working life of the product may also be shorter than the assumed working life.



SHERPA Power Base is made of structural steel S235 according to EN 10025-2 or better and galvanised with Z275 or equivalent. The screws for installation as well as the hexagon socket head cap screws are made of carbon steel and galvanised, too.

#### 3.1.3 Reaction to fire

SHERPA Power Base is made of structural steel S235 and the screws are made of carbon steel, both classified as Euroclass A1 in accordance with Commission Decision 96/603/EC as amended.

#### 3.2 Assessment methods

#### 3.2.1 General

The assessment of the essential characteristics in Clause 3.1 of SHERPA Power Base for the intended use, and in relation to the requirements for mechanical resistance and stability and for safety in case of fire in the sense of the basic requirements for construction works № 1 and 2 of Regulation (EU) № 305/2011 has been made in accordance with the European Assessment Document EAD 130186-00-0603 "Three-dimensional nailing plates".

#### 3.2.2 Identification

The European Technical Assessment for SHERPA Power Base is issued on the basis of agreed data that identify the assessed product. Changes to materials, to composition, to characteristics of the product, or to the production process could result in these deposited data being incorrect. Österreichisches Institut für Bautechnik should be notified before the changes are implemented, as an amendment of the European Technical Assessment is possibly necessary.

# 4 Assessment and verification of constancy of performance (thereinafter AVCP) system applied, with reference to its legal base

#### 4.1 System of assessment and verification of constancy of performance

According to Commission Decision 97/638/EC the system of assessment and verification of constancy of performance to be applied to SHERPA Power Base is System 2+. System 2+ is detailed in Commission Delegated Regulation (EU) № 568/2014 of 18 February 2014, Annex, 1.3., and provides for the following items

- (a) The manufacturer shall carry out:
  - an assessment of the performance of the construction product carried out on the basis of testing (including sampling), calculation, tabulated values or descriptive documentation of that product;
  - (ii) factory production control;
  - (iii) testing of samples taken at the manufacturing plant by the manufacturer in accordance with a prescribed test plan<sup>5</sup>.
- (b) The notified factory production control certification body shall decide on the issuing, restriction, suspension or withdrawal of the certificate of conformity of the factory production control on the basis of the outcome of the following assessments and verifications carried out by that body:
  - (i) initial inspection of the manufacturing plant and of factory production control;
  - (ii) continuing surveillance, assessment and evaluation of factory production control.

<sup>&</sup>lt;sup>5</sup> The prescribed test plan has been deposited with Österreichisches Institut für Bautechnik and is handed over only to the notified factory production control certification body involved in the procedure for the assessment and verification of constancy of performance. The prescribed test plan is also referred to as control plan.



# 4.2 AVCP for construction products for which a European Technical Assessment has been issued

Manufacturers undertaking tasks under System 2+ shall consider the European Technical Assessment issued for the construction product in question as the assessment of the performance of that product. Manufacturers shall therefore not undertake the tasks referred to in point 4.1 (a)(i).

# 5 Technical details necessary for the implementation of the AVCP system, as provided for in the applicable European Assessment Document

#### 5.1 Tasks for the manufacturer

5.1.1 Factory production control

In the manufacturing plant the manufacturer shall establish and continuously maintain a factory production control. All procedures and specification adopted by the manufacturer shall be documented in a systematic manner. The factory production control shall ensure the constancy of performances of SHERPA Power Base with regard to the essential characteristics.

The manufacturer shall only use raw materials supplied with the relevant inspection documents as laid down in the control plan. The incoming raw materials shall be subject to controls by the manufacturer before acceptance. Check of incoming materials shall include control of inspection documents presented by the manufacturer of the raw materials.

The frequencies of controls conducted during manufacturing and on the assembled product are defined by taking account of the manufacturing process of the product and are laid down in the test plan.

The results of factory production control are recorded and evaluated. The records include at least the following data:

- Designation of the product, basic materials and components
- Type of control or test
- Date of manufacture of the product and date of testing of the product or basic materials or components
- Results of controls and tests and, if appropriate, comparison with requirements
- Name and signature of person responsible for factory production control

The records shall be kept at least for ten years time after the construction product has been placed on the market and shall be presented to the notified factory production control certification body involved in continuous surveillance. On request they shall be presented to Österreichisches Institut für Bautechnik.

#### 5.1.2 Declaration of performance

The manufacturer is responsible for preparing the declaration of performance. When all the criteria of the assessment and verification of constancy of performance are met, including the certificate of conformity of the factory production control issued by the notified factory production control certification body, the manufacturer shall draw up a declaration of performance.



### 5.2 Tasks for the notified factory production control certification body

5.2.1 Initial inspection of the manufacturing plant and of factory production control

The notified factory production control certification body shall verify the ability of the manufacturer for a continuous and orderly manufacturing of SHERPA Power Base according to the European Technical Assessment. In particular the following items shall be appropriately considered

- Personnel and equipment
- The suitability of the factory production control established by the manufacturer
- Full implementation of the test plan
- 5.2.2 Continuing surveillance, assessment and evaluation of factory production control

The notified factory production control certification body shall visit the factory at least once a year for routine inspection. In particular the following items shall be appropriately considered

- The manufacturing process including personnel and equipment
- The factory production control
- The implementation of the control plan

The results of continuous surveillance are made available on demand by the notified factory production control certification body to Österreichisches Institut für Bautechnik. When the provisions of the European Technical Assessment and the control plan are no longer fulfilled, the certificate of conformity of the factory production control is withdrawn by the notified factory production control certification body.

Issued in Vienna on 26.02.2021 by Österreichisches Institut für Bautechnik

The original document is signed by:

Rainer Mikulits

Managing Director



SHERPA special screw 8 x 160/180 mm			
Tensile strength	$\geq$ 600 N/mm <sup>2</sup>		
E-Modulus	210 000 N/mm <sup>2</sup>		
Head diameter d <sub>k</sub>	15 mm		
Outer thread diameter d <sub>1</sub>	8 mm		
Inner thread diameter d <sub>2</sub>	5.3 mm		
Flange diameter d <sub>3</sub>	7.8 mm		
Length L	160 or 180		
Pitch P	3.6 mm		
Milling length A	11 mm		
Center distance B	0.1 mm		





SHERPA Power Base	Annex 1
Fastener specification – special screws	of European Technical Assessment ETA-15/0540 of 26.02.2021



#### Power Base C, S and F

Power Base	a in mm <sup>1)</sup>	Base plate 2)	End plate <sup>3)</sup>	Special screws
Type L 130 C	150 - 200			
Type L 140 C	150 - 200	Type 1 or Type 2	Type A to Type E thickness 12 mm	
Type L 170 S	150 - 200			
Type XL 120 C	200 - 300			Ø 8 mm x 160 mm
Type XL 140 C	200 - 300			Ø 8 mm x 180 mm
Type M 125 F	90 - 130	100 x 160 x 10 mm		
Type L 125 F	150 – 200	with 4 boreholes Ø 15 mm	Type A to Type E	
Type XL 95 F	200 - 300			

<sup>1)</sup> a ... distance between basement and end plate

#### <sup>2)</sup> Base plate

Type 1: 140 x 140 x 12 mm with 4 bore holes Ø 15 mm

Type 2: 140 x 140 x 12 mm with 3 slotted holes 15 x 30 mm and 1 bore hole Ø 15 mm

#### <sup>3)</sup> End plate

Type A: Ø 96 mm with 3 inclined bore holes Ø 9 mm

Type B: Ø 106 mm with 3 inclined bore holes Ø 9 mm

- Type C:  $\emptyset$  116 mm with 3 inclined bore holes  $\emptyset$  9 mm
- Type D:  $\emptyset$  126 mm with 3 inclined bore holes  $\emptyset$  9 mm

Type E: 100 x 100 with 3 inclined bore holes  $\emptyset$  9 mm and 1 bore hole  $\emptyset$  9 mm

SHERPA Power Base	Annex 2
Specification – Power Base	of European Technical Assessment ETA-15/0540 of 26.02.2021



















Product details definitions: Power Base XL 120 C	of European Technical Assessment ETA-15/0540 of 26.02.2021





















electronic copy





electronic copy







	Characteristic load bearing capacity in compression and tension		
End plate	R1,k,compression <sup>1)</sup>		
-	Wood failure	Steel failure	
	kN	kN	
Ø 96 mm	152		
Ø 106 mm	185	According to Type of Power	
Ø 116 mm	222		
Ø 126 mm	262	Base	
100 x 100	210		
<ol> <li>It has to be checked whether wood failure or steel failure is decisive</li> </ol>			

	End plate	Characteristic load bearing capacity in compression and tension		
Bower Booo		R <sub>1,k,compression</sub> <sup>1)</sup>	R <sub>1,k,tension</sub> <sup>1) 2)</sup>	
Fower base		Steel failure	Wood failure	Steel failure <sup>3)</sup>
		kN	kN	kN
Type M 125 F	A, B, C, D, or E	125		37.7
Type L 125 F	A, B, C, D, or E	129	Screw length	37.7
Type L 130 C	A, B, C, D, or E	129	l = 160 mm:	-
Type L 140 C	A, B, C, D, or E	138	32.6	-
Type L 170 S	A, B, C, D, or E	174	Screw length	-
Type XL 95 F	A, B, C, D, or E	95	I = 180 mm:	37.7
Type XL 120 C	A, B, C, D, or E	120	40.2	-
Type XL 140 C	A, B, C, D, or E	138		-
<sup>1)</sup> It has to be checked whether wood failure or steel failure is decisive				

<sup>2)</sup> The characteristic load bearing capacity is only valid in short-term and instantaneous loadduration classes

<sup>3)</sup> Failure of hexagon socket head cap screws

SHERPA Power Base	Annex 5
Characteristic load bearing capacities and stiffness	of European Technical Assessment ETA-15/0540 of 26.02.2021



		Characteristic lateral load bearing capacity		
Dower Booo	End plate	R <sub>23;45,k</sub> <sup>1)</sup>		
Power Base	End plate	Wood failure	Steel failure	
		kN	kN	
Туре М 125 F	A, B, C, D, or E	-	2.03	
Type L 125 F	A, B, C, D, or E	-	2.03	
Type L 130 C	A, B, C, D, or E	4.28 <sup>2)</sup>	6.38	
Type L 140 C	A, B, C, D, or E	5.26	4.48	
Type L 170 S	A, B, C, D, or E	-	5.91	
Type XL 95 F	A, B, C, D, or E	-	2.03	
Type XL 120 C	A, B, C, D, or E	2.15 <sup>2)</sup>	3.82	
Type XL 140 C A, B, C, D, or E		5.26	4.48	
<sup>1)</sup> It has to be checked whether wood failure or steel failure is decisive				
<sup>2)</sup> Wood failure is decisive				

Wood failure is calculated for timber strength class C24.The characteristic load-bearing capacities for wood failure are given for a characteristic density of 350 kg/m<sup>3</sup>. For timber with a higher characteristic density than 350 kg/m<sup>3</sup> the characteristic load bearing capacities may be adapted by by the factor  $k_{dens}$ 

 $k_{dens} = (\rho_k / 350)^{0.8}$ 

Where

 $k_{dens}$ ....Factor to consider deviating densities

 $\rho_k.....$  Characteristic density of timber in kg/m³

SHERPA Power Base	Annex 5
Characteristic load bearing capacities and stiffness	of European Technical Assessment ETA-15/0540 of 26.02.2021



European Assessment Document EAD 130186-00-0603 "Three-dimensional nailing plates".

EN 338 (04.2016), Structural timber – Strength classes

EN 1990 (04.2002), +AC (12.2008), +AC (04.2010), Eurocode – Basis of structural design

EN 1995-1-1 (11.2004), +AC (06.2006), +A1 (06.2008), +A2 (05.2014), Eurocode 5 – Design of timber structures - Part 1-1: General – Common rules and rules for buildings

EN 10025-2 (08.2019), Hot rolled products of structural steels – Part 2: Technical delivery conditions for non-alloy structural steels

EN 14080 (06.2013), Timber structures – Glued laminated timber and glued solid timber – Requirements

EN ISO 12944-2 (12.2017), Paints and varnishes – Corrosion protection of steel structures by protective paint systems – Part 2: Classification of environments

SHERPA Power Base	Annex 6
Reference documents	of European Technical Assessment ETA-15/0540 of 26.02.2021